

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 641

Dated: 08/04/24

It is certified that an inspection team headed by BRINHASPATI YADAV

Name of Officers with designation) from PHED, Siwan (Name of Department/ Office)

inspected the SHREE RAM KRISHNA MISSION HIGH SCHOOL, RAM KRISHNA NAGAR,

CHAPRA ROAD, SIWAN (Name & Address of the school) on 08.04.2024 (date of inspection),

and on the basis of Water Test report (attached) bearing no. DLWTL/24

Dated: 06.04.2024 of District Level Water Testing Laboratory, Siwan (PHED LAB)

certified that the SHREE RAM KRISHNA MISSION HIGH SCHOOL has safe drinking water facilities for the students and member of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The certificate is valid till 08.04.2025


08/04/24

Signature with Seal:
Assistant Engineer
P.H. Sub-Division, Siwan

Name: Kishore Kumar

Designation: Assistant Engineer


Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body
Name & Address of the Office / Department:
PHED, SIWAN

To,

SHREE RAM KRISHNA MISSION HIGH SCHOOL

RAM KRISHNA NAGAR, CHAPRA ROAD, SIWAN.


Principal
Shree Ramkrishna Mission High School
Chhapra Road, Ramkrishna Nagar
Siwan, Bihar-841226


Manager
Shree Ramkrishna Mission High School
Chhapra Road, Ramkrishna Nagar
Siwan, Bihar-841226

Government of Bihar
Public Health Engineering Department
District Level Water Testing Laboratory :- Siwan

Ref: DLWTL/24

Simple Collected By- Shree Ram Krishna Mission High School, Siwan

Simple Receiving Date:- 02-04-2024

Sl No.	Date of Testing	Block	Panchayat	Ward	Name of Scheme	Parameters																		
						pH	Turb.	EC	TDS	TH	Cu	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Total Coli				
1	03-04-2024	Siwan	Siwan Sadar	-	Shree Ram Krishna Mission High School	7.24	1.0	-	430	188.2	52.2	12.6	82.0	192.0	0.29	BDL	20	BDL	0.20	<1.1				
IS: 10500:2012 (2 ND Revision)						Accetable Limit					6.5-8.5	1.0	-	200	200	75	30	250	200	0.3	45	200	1.0	0.01
						Permissible Limits					8.5	5.0	-	500	600	200	100	1000	600	1.0	NR	400	1.5	NR

[Signature]
 Chemist

D.L.L.P.H. Division, Siwan

[Signature]
 Principal

Shree Ramkrishna Mission High School
 Chhapra Road, Ramkrishna Nagar
 Siwan, Bihar-841226

[Signature]
 Manager

Shree Ramkrishna Mission High School
 Chhapra Road, Ramkrishna Nagar
 Siwan, Bihar-841226